



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

AUG 1 2014

Ms. Carla Emery &
Ms. Anna Parks
Country View Restaurant
13877 State Route 118
Unityville, Pennsylvania 17774

RE: Notice of Violation, Docket No. SDWA-03-2014-017-VS
Country View Restaurant Water System, Unityville, Lycoming County,
Pennsylvania
PWS ID No. PA4410938

Dear Ms. Emery and Ms. Parks,

The following Notice of Violation is issued pursuant to Sections 1414(a) and 1445 of the Safe Drinking Water Act (SDWA), 42 U.S.C. §§ 300g-3(a) and 300j-4(a), and is a coordinated effort with the Pennsylvania Department of Environmental Protection (PADEP). According to our records and information received from PADEP, your public water system has violated certain provisions of the SDWA, 42 U.S.C. §§ 300f-300j-26, the National Primary Drinking Water Regulations (NPDWR) found at 40 Code of Federal Regulations (CFR) Part 141.

NOTICE OF VIOLATION

FINDINGS

Based on information we possess:

1. Carla Emery and Anna Parks are the owners of the Country View Restaurant public water system (PWS), PWS Identification Number PA4410938 (System). Respondents are "persons" as defined by Section 1401 (12) of the SDWA and 40 C.F.R. § 141.2.
2. The System serves a population of at least twenty-five (25) persons daily with piped water for human consumption for a minimum of sixty (60) days per year, and/or has at least fifteen (15) service connections.
3. Respondents failed to monitor for total coliform bacteria, as required by 40 C.F.R. § 141.21(a) during the quarterly monitoring period beginning October 2013.
4. Respondents failed to monitor for nitrate and nitrite, as required by 40 C.F.R. § 141.23 during the annual compliance period beginning January 2012 and January 2013.

names, titles, and addresses of officers. The street address of the System, or, if no street address is possible, the physical location of the System. Do not provide a post office box.

3. Number of persons served drinking water by the System per day on average.
4. Number of service connections to System.
5. State whether the System is operated year-round. If the System is not operated year-round, state the number of days in operation.
6. A copy of the most recently performed sanitary survey for the System.
7. Copies of any total coliform laboratory analyses performed since October 2013.
8. Copies of any nitrate laboratory analyses performed since January 2012.
9. Copies of any public notification posted or provided to water users, regarding the violations listed in paragraphs 3 and 4 of the Findings.
10. Copies of any reports forwarded to PADEP concerning violations and public notifications for the violations listed in paragraphs 3 and 4 of the Findings.
11. Any existing plans and schedules for monitoring, reporting and public notification.
12. Your response to this Notice of Violation and Request for Information shall be in writing.
13. Your response is due within thirty (30) days of receipt of this Notice of Violation and Request for Information. You should submit your response to:

Ms. Roberta Riccio
United States Environmental Protection Agency
Ground Water and Enforcement Branch (3WP22)
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029
Riccio.roberta@epa.gov

and
Mr. John Hamilton
Environmental Group Manager
Safe Drinking Water
Pennsylvania Department of Environmental Protection
DEP North-Central Regional Office
208 West Third St.
Williamsport, PA 17701
570-327-3636

If you have any questions, please call Roberta Riccio at 215-814-3107.